

## PRR 153 Next Steps Discussion

### EWWG Meeting #29 January 30<sup>th</sup>, 2026


#### Background:

To progress with PRR153 NYISO consulted DNV to provide analysis of sudden outages for Land Based Wind (LBW), Offshore Wind (OSW), Utility Solar (UPV), and Behind-the-Meter Solar (BTM).

DNV presented the results of their analysis and recommendations during EWWG Meeting #28 (December 19<sup>th</sup>, 2025).


#### Key Takeaways:

- For the analysis sudden outage events were defined as a ramp down of at least 25% project capacity over a 15-minute period.
- Statistics of all 15-Minute Down Ramps were provided:
  - LBW: 99.4% are < 25% capacity: (103 per yr / project)
  - OFW: 98.9% are < 25% capacity: (190 per yr / project)
  - UPV: 98.5% are < 25% capacity: (132 per yr / project)
  - BTM: 99.6% are < 25% capacity: (32 per yr / county)
- Down Ramps with  $\geq$  90% Capacity:
  - LBW: ~ 1 per year / project
  - OSW: 4 per year / project
  - UPV: ~ 1 per year / project
  - BTM\*: < 1 per year / county
- DNV investigated spatial and temporal covariance of sudden production drops providing quantification of covariance decay by distance for a project.



- Table of covariance (%) by distance and useful visualizations were also provided:

Resource Type	±15 Minutes						
	Distance						
	1 km	3 km	5 km	10 km	20 km	50 km	100 km
LBW	88%	71%	59%	42%	27%	14%	8%
OSW	100%	100%	100%	73%	44%	23%	14%
UPV	80%	69%	60%	46%	33%	19%	13%
BTM	89%	73%	62%	46%	30%	16%	10%



- Contingency recommendations utilized an expected loss using covariance as probability of loss:
  - Per Project Expected Loss = Probability x MW Loss
  - Aggregate Total Expected Loss =  $\sum$  Per Project Expected Loss
- Examples of an expected loss contingency were provided:

## OSW 2030 Contingency: High Wind Shutdown

### • High Wind Shutdown

- Strong winds: Projects generating at max capacity
- Highest risk: **November – April**
  - overlaps light load periods

OSW: 9,000 MW for 2030-2040					
Project	2030 Capacity (MW)	Distance (km)	Probability of Coincidence	90% Loss (MW)	Expected Loss (MW)
WindFarm1	2,100	0	100%	1,890	1,890
WindFarm2	390	45	25%	351	87
WindFarm5	1,260	57	21%	1,134	237
WindFarm7	5,250	82	16%	4,725	769

*Expected Loss = probability of coincidence  $\times$  MW loss*

$$\text{Total Expected Loss} = \sum \text{Expected Loss}$$

### • Full Outage ( $\geq$ 90% of capacity)

- **Single Project Loss**
  - Wind Farm 1: Loss of 1,890 MW
- **Multi-Project Loss:** Within 60 km  $\longrightarrow$  Windfarms 1, 2, 5
  - Possible Loss (90% cap): 3,375 MW
  - Total Expected Loss: 2,213 MW

### • For each OSW project:

- $\geq 25\%$  cap loss occurs average of 28 times per year
- $\geq 90\%$  loss occurs average of 3 times per year

## Discussion and Next Steps:

EWWG needs to provide RRS an update on whether enough data is available to adopt PRR 153

- Would we recommend application of the analysis to planning criteria, operating rules, or both?
- What other data is necessary?
  - Defining probabilistic basis for criteria
  - Further spatial covariance data
  - More detailed temporal covariance with load by season
  - Planning case test data
- At the EC Meeting #321 (January 14<sup>th</sup>, 2026) NYISO VP of System and Resource Planning Zach Smith asked whether these sudden ramp down events should be raised to being considered design contingencies? Is mitigation appropriate?
  - NYISO Members mentioned that mitigations are possible with wind speed forecasting provided to NYISO Operations.