

**NYSRC - Reliability Rules Subcommittee (RRS)
Potential Reliability Rule Changes – Outstanding
(As of February 5, 2026)**

PRR No.	Existing Rule	Potential Rule Change	Sponsor(s)	Category ¹	Status ²	RRS Action
PRR 153	New Contingency requirement for B.1 - Transmission System Planning Performance Requirements, R1 - Transmission facilities in the NYS Bulk Power System shall be planned to meet the respective performance requirements in Table B-1 and supplemental performance requirements in Table B-2 for the contingency events as specified in Table B-1.	Include "Sudden loss of fuel delivery system to multiple solar & wind plants" as Category I & II Design Contingencies in Table B-1	NYISO RRS EWWG	R	1	In development

¹ Categories: **R**=Rule; **D**=Definition; **RQ**=Requirement; **P**=Procedure/Guideline; **C**=Compliance Elements; **E**=Exception

² Status: **1**=In RRS for development/review; **2**=In RCMS for compliance elements; **3**=To EC for approval to post; **4**=Approved by EC for posting; **5**=RRS incorporating comments from posting; **6**=To EC for final approval; **7**=Approved by EC; **8**=Removed