

New York State Reliability Council – Extreme Weather Working Group (EWWG)
Meeting # 28 Minutes – December 19, 2025
Zoom

1. Draft Meeting Minutes for Meeting #27 – Emmanuel Panaligan

- Updated and approved.

2. PRR-153 Progress Check In – Roger Clayton

- R. Clayton explained that PRR153 Item 3 Revision to B.1 states a change will be made to Requirement R1 stating “NYS BPS shall be planned to meet the respective performance requirements in Table B-1”. However, sudden loss of generation due to weather is undefined and needs clarification in an associated guideline as to the extent in location, time and coincidence.

3. DNV PRR-153 Presentation – DNV and Chris Hayes

- Chris Hayes from DNV presented an overview of the results and recommendations of their Renewable Resource Sudden Outage Analysis requested by NYISO to progress on PRR-153.
- R. Clayton suggested adding scenarios of real-world applications to give planners more insight on the impact.
- D. Kirk-Davidoff asked if there has been any discussion on performing the study based on the transmission network, such as dividing the system into nodes rather than the current arbitrary spatial groupings.
 - Chris acknowledged that it has been discussed as a possible next step.
- H. Athar inquired about a timeline plan and Chris explained that DNV is working to release drafts to NYISO early 2026 with the next step primarily focusing on building out the 2030 scenarios described in the presentation.