

NYISO Self-Certification

NYSRC Reliability Rule:

C.8: Real-Time Operations of the NYS Bulk Power System

NYSRC Requirement(s) for which compliance is being self-certified

R1 The NYISO shall provide a monthly operations report to the NYSRC that provides data on the performance of the NYCA for the previous month, covering the following requirements:

- R1.1** Occurrences of major *emergency* and alert states.
- R1.2** Summary of the NERC/NPCC Control Performance.
- R1.3** A list of NPCC Reportable Events.
- R1.4** Reserve requirements and actual reserves for the monthly peak *load* hour for all reserve categories (10 minute synchronized, 10 minute non-synchronized, and 30-minute *operating reserves*). The report shall distinguish between supply and demand side *resources*.
- R1.5** The response of the system to activations of *reserve*, including: the number of occasions reserves were activated in the month, reasons for the *reserve* activations, number of occasions within the month in which the *reserve* activation did not result in an area control error (“ACE”) zero crossing, number of non-zero crossings associated with a unit loss, and number of non-zero crossings requiring another *reserve* activation.
- R1.6** A report of the number of more stringent events in which operating restrictions were imposed, resulting in an Alert or *Major Emergency* state due to severe weather conditions and/or severe solar magnetic *disturbances*.
- R1.7** *Emergency* actions initiated, including: *emergency* assistance from neighboring *Control Areas*, manual (local) *voltage reductions*, quick response (remote control) *voltage reductions* (5 and 8%), voluntary *load* curtailment, public appeals, Special Case Resources, Emergency Demand Response Program, and *load shedding*. For each *emergency* action the report shall include: (a) the date of the *emergency* action; (b) the *zone(s)* where the *emergency* action was implemented; (c) an estimate of the MW *capacity* addition or *load relief* achieved, by *zone*; and (d) the reason(s) why the *emergency* action was implemented.
- R1.8** Other analyses and indices identified by the NYSRC Executive Committee for monitoring the *security* of the system.

Measure No.

<input checked="" type="checkbox"/> Full Compliance	M1. The NYISO submitted a monthly operations report covering the previous month in accordance with requirements defined in R1.1 to R1.8.
---	---

Levels of Non-Compliance

_____ Level 1	M1. The <i>NYISO</i> submitted a monthly operations report, but the report was incomplete relative to one of the Requirements defined in R1.1 to R1.8.
_____ Level 2	M1. The <i>NYISO</i> submitted a monthly operations report, but the report was incomplete relative to two of the Requirements defined in R1.1 to R1.8.
_____ Level 3	M1. The <i>NYISO</i> submitted a monthly operations report, but the report was incomplete relative to three or more of the Requirements defined in R1.1 to R1.8.
_____ Level 4	M1. The <i>NYISO</i> failed to submit a monthly operations report for the previous month.

Compliance Monitoring Process

<p>Compliance Monitoring Responsibility:</p> <ul style="list-style-type: none">• M1: RCMS <p>Compliance Documentation Reporting Frequency:</p> <ul style="list-style-type: none">• M1: Monthly <p>Compliance Reporting Requirements:</p> <ul style="list-style-type: none">• M1: Monthly operations report
--

Reliability Rule C.8 R1 Narrative:

NYISO provided the Monthly Operations Report for January 2026.

Certified by: Gregory Campoli

Title: Manager, Reliability Compliance and Industry Affairs

Date: March 5, 2026