

**NYSRC - Reliability Rules Subcommittee (RRS)
Potential Reliability Rule Changes – Outstanding
(As of April 2, 2026)**

PRR No.	Existing Rule	Potential Rule Change	Sponsor(s)	Category ¹	Status ²	RRS Action
PRR 153	New Contingency requirement for B.1 - Transmission System Planning Performance Requirements, R1 - Transmission facilities in the NYS Bulk Power System shall be planned to meet the respective performance requirements in Table B-1 and supplemental performance requirements in Table B-2 for the contingency events as specified in Table B-1.	Include "Sudden loss of fuel delivery system to multiple solar & wind plants" as Category I & II Design Contingencies in Table B-1	NYISO RRS EWWG	R	1	In development
PRR 157		Create Statewide Implementation Plan to authorize participation of Large Load interconnections in Transmission Owner Under Frequency Load Shedding programs	RRS	R		

¹ Categories: **R**=Rule; **D**=Definition; **RQ**=Requirement; **P**=Procedure/Guideline; **C**=Compliance Elements; **E**=Exception

² Status: **1**=In RRS for development/review; **2**=In RCMS for compliance elements; **3**=To EC for approval to post; **4**=Approved by EC for posting; **5**=RRS incorporating comments from posting; **6**=To EC for final approval; **7**=Approved by EC; **8**=Removed

PRR No.	Existing Rule	Potential Rule Change	Sponsor(s)	Category ¹	Status ²	RRS Action
PRR 158	Resolve Difference between NYSRC Reliability Rule Table B-1 and NPCC Directory 1, Table 1, and NERC Standard TPL-001-5.1, Table 1 regarding Multiple Tower Exclusion Criteria	Modify note vii. to Table B-1: with: vii. Regarding contingency no 6, if multiple circuits share common structures for a cumulative length of one mile or less, then this condition is an acceptable risk and therefore can be excluded. For instances where single (non-consecutive) structures are shared along the route, half of the length of the longest single span attached to the multiple circuit tower structure should be included for the purpose of determining the cumulative length. Other similar situations can be excluded on the basis of acceptable risk, provided that the NYSRC Executive Committee specifically accepts each request for exclusion.	RRS National Grid	R	1	In development