

# Generator Transition Rate Matrices: Impact Analysis

---

Bianca Prinsloo

ICS Meeting #317

June 3, 2026

# Background

- Effective October 2025, the NYISO transitioned to a new generator availability data reporting software known as PowerGADS, following the retirement of the Generator Availability Data System Open Source (GADS OS) software.
  - Benchmarking of PowerGADS was presented at the April 28, 2026 ICS meeting.<sup>1</sup>
  - ICS members requested an impact breakdown of the transition to PowerGADS and the update to the 5-year average EFORdAPA<sup>2</sup> from 2020-2024 data to 2021-2025 data.
- The purpose of today's presentation is to review preliminary results.

1. [https://www.nysrc.org/wp-content/uploads/2026/04/PowerGADS\\_MARS\\_Matrices-04282026-ICS.pdf](https://www.nysrc.org/wp-content/uploads/2026/04/PowerGADS_MARS_Matrices-04282026-ICS.pdf)

2. EFORdAPA is a resultant metric using the capacity states and transitional probabilities that are directly used in the MARS model.

# Transition to PowerGADS

# Transition to PowerGADS Impact

- **To assess the impact of the transition to PowerGADS, the NYISO conducted a parametric assessment of the impact using the 2026-2027 IRM Final Base Case (FBC) Special Sensitivity Case.**
  - The assessment is conducted using the updated transition matrix from PowerGADS, with the same GADS data used for the transition matrix in the 2026-2027 IRM FBC Sensitivity Case (2020-2024)
  - Updated EFORD calculated with PowerGADS is also used in the parametric assessment
  
- **The transition to PowerGADS produced a modest increase in the IRM, reflecting incremental changes in how forced outage behavior is represented with the new PowerGADS. The overall impact is limited in magnitude.**
  - As discussed at the April 28, 2026 ICS meeting, the PowerGADS system includes software differences and deliberate codes enhancements compared to the GADS OS.

Case	IRM (%)	J LCR (%)	K LCR (%)	G-J LCR (%)
2026-2027 IRM FBC Special Sensitivity Case (with GADS OS transition matrix using 2020-2024 data)	25.60	79.85	107.50	89.22
Parametric Test Case for PowerGADS Transition (with PowerGADS transition matrix using 2020-2024 data)	25.75	79.88	107.64	89.30
<i>Delta</i>	<i>+0.15</i>	<i>+0.03</i>	<i>+0.14</i>	<i>+0.08</i>

# 5-Year Outage Data Update *(2020-2024 vs. 2021-2025)*

# 5-Year Outage Data Update

- For the 2027-2028 IRM study, generator outage data will be updated from the 2020-2024 dataset to 2021-2025 dataset.
  - The transition matrix will be updated with the 2020 data rolled off and 2025 data rolled in.
- The NYISO reviewed the forced outage data between 2020 and 2025 and concluded that forced outages in 2025 were significantly higher than 2020 (discussed further on the next slide).
- Therefore, when updating the 5-year outage data for the 2027-2028 IRM Preliminary Base Case (PBC), the IRM and locational requirements increased in the range of 1%-2%.
  - Such impact is consistent with the changes in the underlying fleet performance assumption.
  - Load Zones J, K and the G-J Locality experienced the largest impacts, consistent with the fleet's performance in the respective areas.


Case	IRM (%)	J LCR (%)	K LCR (%)	G-J LCR (%)
2026-2027 IRM FBC Special Sensitivity Case (with GADS OS transition matrix using 2020-2024 data)	25.60	79.85	107.50	89.22
Parametric Test Case with Updated Outage Data <sup>3</sup> (with PowerGADS transition matrix using 2021-2025 data)	26.90	81.28	109.53	90.81
<i>Delta</i>	+1.30	+1.43	+2.03	+1.59

3. The reported results reflect two changes: (1) transitioning from GADS OS to PowerGADS, and (2) the outage data update. (see Slide 4 for the impact assessment specifically due to the PowerGADS transition).

# Zonal Forced Outage Comparison (2020 vs 2025)

- 2025 forced outage levels are significantly higher than 2020 across multiple zones, driven by increased frequency and duration of forced outage events.
- This is consistent with the increase in derates observed in the NYISO's Summer 2026 Capacity Assessment.<sup>4</sup>
  - The assessment notes a 580 MW reduction in the capacity margin for the baseline assessment and 407 MW increase in the assumed level of unavailable capacity relative to the 2025 assessment.
- The below chart highlights the material increase in forced outage hours in 2025 compared to 2020 across Load Zones G through K

Zonal Average Weighted Forced Outage Hours



\*Weighted by summer Net Dependable Capacity (NDC)

■ 2020 Average Weighted Forced Outage Hours

■ 2025 Average Weighted Forced Outage Hours

4. <https://www.nyiso.com/documents/20142/57796669/S2026%20Capacity%20Assessment%20for%200C.pdf>

# Observations & Next Steps

- **The new PowerGADS software is largely comparable to the historic GADS OS system, producing consistent inputs for the IRM study model**
- **Updating the 5-year outage data has a material impact on the IRM, due to significantly higher forced outage levels included in the updated dataset**
- **Next Steps:**
  - Proceed with the 2027-2028 IRM PBC study and incorporate both the transition to PowerGADS and the most recent 5-year outage dataset in the base case.
  - Present parametric study results at the July 8, 2026 ICS meeting.

# Questions?

# Our Mission and Vision



## Mission

Ensure power system reliability and competitive markets for New York in a clean energy future



## Vision

Working together with stakeholders to build the cleanest, most reliable electric system in the nation

