



Operations Performance Metrics Monthly Report

A Report by the
New York Independent System Operator

June 2026

*Prepared by NYISO Operations Analysis and Services, based on settlements
initial invoice data collected on or before July 9, 2026.*

Table of Contents

JUNE 2026 HIGHLIGHTS	3
NYCA GENERATION MIX	4
RELIABILITY PERFORMANCE METRICS	5
Alert State Declarations	
Major Emergency State Declarations	
Reserve Activiations	
IROL Exceedance Times	
Disturbance Recovery Times	
Balancing Area Control Performance	
Thunderstorm Alert Hours	
Transmission Loading Relief Hours	
Load Forecasting Performance	
Net Load Ramp Trends	
Wind Forecasting Performance	
FTM Solar Forecasting Performance	
BTM Solar Forecasting Performance	
Net Wind & Solar Performance	
DAM Capacity Unavailable	
Lake Erie Circulation and ISO Schedules	
Desired Net Interchange Trends	
MARKET PERFORMANCE METRICS.....	13
RTM Congestion Residuals Monthly Trend	
RTM Congestion Residuals Daily Costs	
RTM Congestion Residuals Cost Categories	
RTM Congestion Residuals Event Summary	
DAM Congestion Residuals Monthly Trend	
DAM Congestion Residuals Daily Costs	
DAM Congestion Residuals Cost Categories	
NYCA Power Supplier Uplift Monthly Trend	
NYCA Power Supplier Uplift Daily Costs	
Local Reliability Costs Monthly Trend	
Local Reliability Monthly DARU & SRE Hours	
TCC Monthly Clearing Price with DAM Congestion	
ICAP Spot Market Clearing Price & Price Change Summary	
APPENDIX	21
Appendix A – Metric Definitions	
Appendix B – NYISO Information Resources	



June 2026 Highlights

			
Monthly Metered Load		Historical Metered Load Peaks	
Peak Load	Minimum Load	Summer 2026 Peak Load	All-Time Summer Peak Load
27,545 MW 06/11/2026 HB 17	12,441 MW 06/02/2026 HB 03	27,545 MW 06/11/2026 HB 17	33,956 MW 07/19/2013 HB 16
Monthly Intermittent Resource Peaks		Historical Intermittent Resource Peaks	
			
Peak Wind	Peak Solar (FTM+BTM)	All-Time Peak Wind	All-Time Peak Solar (FTM+BTM)
2,140 MW 06/18/2026 HB 18	5,661 MW 06/03/2026 HB 12	2,389 MW 10/31/2025 HB 14	5,661 MW 06/03/2026 HB 12

Notable NYCA System Events

- Effective 6/1, the Transmission Reliability Margins (TRMs) for the PJM and IESO interfaces have been increased from 300MW to 350MW due to changes in Lake Erie Circulation uncertainty assumptions.
- At its meeting on 6/12, the NYSRC Executive Committee approved [Reliability Rule #159](#), formalizing 'Emergency Response Capability' permitting NYISO to more effectively resolve post-contingency overloads on critical underground cables through both increasing and decreasing resource output.
- EDRP/SCR resources activated statewide on 6/11 for HB16 through HB22. Additionally, the Targeted Demand Response Program (TDRP) was activated on 6/14 through 6/17 for constraint management due to the forced outage of the Gowanus-Greenwood 138kV (#42232). See Historic EDRP/SCR Activation [web-posting](#).


NYCA Generation Mix




Reliability Performance Metrics

See [Appendix A](#) for metric definitions


Major Emergency State & Alert State Declarations




Reserve Activations




NERC IROL and DCS Reportable Violation Minutes




NERC Control Performance Standard




NERC Balancing Authority ACE Limit Standard




Thunderstorm Alert Hours and NERC TLR-3 Hours






Load Forecast Performance




Average Hourly Net Load Ramps June 2026







Net Wind and Solar Performance Total Monthly Production and Capacity Factors




Net Wind and Solar Performance Total Daily Production and Capacity Factors




Net Wind and FTM Solar Performance Monthly Energy Curtailment




Net Wind and FTM Solar Performance Monthly Energy Curtailment by Limiting Constraint




Monthly Maximum Day-Ahead Market Capacity Unavailable In Real Time



Daily Day-Ahead Market Capacity Unavailable In Real Time




Lake Erie Circulation and ISO Net Interchange Schedules
Monthly Averages




Interchange schedules with positive values aggravate clockwise Lake Erie Circulation.

Lake Erie Circulation and ISO Net Interchange Schedules
Daily Averages




Interchange schedules with positive values aggravate clockwise Lake Erie Circulation.

Monthly Average Interchange by Proxy




Daily Average Interchange by Proxy June 2026




Market Performance Metrics

Balancing Market Congestion Residual Monthly Uplift Cost Categories



Daily Uplift Cost Categories



Real-Time Balancing Market Congestion Residual Categories


Category	Cost Assignment	Events Types	Event Examples
Storm Watch	Zone J	Thunderstorm Alert (TSA)	TSA Activations
Transmission Outage Mismatch	Market-wide	Changes in DAM to RTM transfers related to transmission outage mismatch	Forced Line Outages, Unit AVR Outages, Early Line Return from Outage
Interface/Facility Rerate - NYISO Security	Market-wide	Changes in DAM to RTM transfers not related to transmission outage	Interface/Facility Rerates due to RTM voltages
Interface Rerate - External Security	Market-wide	Changes in DAM to RTM transfers related to External Control Area Security Events	TLR Events, External Transaction Curtailments
Unscheduled Loop Flows	Market-wide	Changes in DAM to RTM unscheduled loop flows impacting NYISO Interface transmission constraints	DAM to RTM Lake Erie Loop Flow exceeding +/-125MW
M2M Settlement	Market-wide	Settlement result inclusive of coordinated redispatch and Ramapo flowgates	
Cost Not Categorized	Market-wide		
Not Investigated	Market-wide		

Monthly Balancing Market Congestion Report Assumptions/Notes


- 1) Storm Watch Costs are identified as daily total uplift costs
- 2) Days with a value of BMCR less M2M Settlement of \$100K/HR, shortfall of \$200K/Day or more, or surplus of \$100K/Day or more are investigated.
- 3) Uplift costs associated with multiple event types are apportioned equally by hour

Day's investigated in June: 3,10,11,12,18,24,25		
Event	Description	June Dates
	Thunder Storm Alert, Chester-Shoemaker 138kV (#27)	11,12
	Thunder Storm Alert, West 49th Street-Sprainbrook 345kV (#M52)	11
	Thunder Storm Alert, Van Wagner-Leeds 345kV (#92)	12
	Forced Outage of the Dunwoodie-Mott Haven 345kV (#71)	3
	NYCA Active DNI Ramp Limit	10,11,12,24,25
	Derate Freeport-Newbridge 138kV (#461)	3,11,24,25
	Derate Lake Success-Shore Rd 138kV (#368)	3
	Derate Astoria Annex-East 13th Street 345kV (#Q35L) I/o \$SCB:RAINEY(4E):63&BK3N_60M	11
	Derate Elwood-Northport 138kV (#468) I/o NRTHPORT-ELWOOD 138 681	11
	Derate Northport-Pilgrim 138kV (#677)	11
	Derate Stewart Ave-Valley Stream 138kV (#262) I/o FREEPORT-NEWBRIDGE 138 461	11,24,25
	Derate Dunwoodie-Shore Road 345kV (#Y50) I/o SCB:SPBK(RNS2):Y49&M29&Y49_ST	12
	Derate Elwood-Northport 138kV (#678)	12
	Derate Knickerbocker-New Scotland 345kV (#2) I/o TWR:CCRT34&DART44&BK114	12
	Derate Meyer 230kV (#BK4) I/o SIN:CANANDGA-STONYRGE 230 68	18
	Derate Linden-Goethals 230kV (#A2253) I/o SCB:GOETH(8):G23M&26&R26	24,25
	Derate Goethals-Gowanus 345kV (#26)	24,25
	Derate Dysinger-Niagara 345kV (#ND2) I/o NIAGARA -DYSINGER 345 ND1	25
	Derate Stewart Ave-Valley Stream 138kV (#262)	25
	Uprate Scriba-Volney 345kV (#20) I/o SCB:SCRIBA(R935):21&FS-10	3,11,12
	Uprate Scriba-Volney 345kV (#20) I/o SCRIBA -VOLNEY 345 21	10,12
	Uprate Astoria West-Hellgate 138kV (#24051)	11
	Uprate Owens Corning-Sabic 115kV (#9) I/o TWR:FEURABSH 3 &17	11,12
	Uprate Greenbush-Regeneron 115kV (#9) I/o N.SCTLND-KNICRBKR 345 2	12
	Uprate Greenbush-Regeneron 115kV (#9) I/o SCB:KNICRBKR(R2):6&2&Y57	12
	Uprate Greenbush-Regeneron 115kV (#9) I/o SCB:KNICRBKR(R6):6&2&Y57&C1&C2	12
	Uprate Greenbush-Regeneron 115kV (#9) I/o SCB:KNICRBKR(RY57):2&6&Y57&C	12
	Uprate Lowville-Waters Road 115kV (#7) I/o SIN:WATRD-BNVL_TAP-BOONVL_8	12
	PJM AC Active DNI Ramp Limit	3,11,12,25
	PJM AC - NY Scheduling Limit	3,11,12
	NE AC Active DNI Ramp Limit	3,10,11,12
	NE NNC1385 - NY Scheduling Limit	3,12
	NE AC - NY Scheduling Limit	11,12
	HQ_CHAT Active DNI Ramp Limit	11
	HQ_CHAT - NY Scheduling Limit	24,25
	Lake Erie Circulation, DAM-RTM exceeds ±125MW; Central	10,11,12,18,25
	Lake Erie Circulation, DAM-RTM exceeds ±125MW; Central East	10,11

DAM Congestion Residual Monthly Cost Categories




Daily Cost Categories




DAM Congestion Residual Categories			
Category	Cost Assignment	Events Types	Event Examples
NYTO Outage Allocation	Responsible TO	Direct allocation to NYTO's responsible for transmission equipment status change.	DAM scheduled outage for equipment modeled in-service for the TCC Auction.
Incremental TCC/External Outage Impacts	All TO by Monthly Allocation Factor	Allocation associated with transmission equipment status change caused by change in status of external equipment or change in status of equipment associated with Incremental TCC.	Tie line required out-of-service by TO of neighboring control area.
Central East Commitment Rerate	All TO by Monthly Allocation Factor	Changes in the DAM Central East_VC limit as compared to the TCC Auction limit, which are not associated with transmission line outages.	
Cost Not Categorized	All TO by Monthly Allocation Factor		


Monthly Power Supplier Uplift Components




June 2026 Daily NYCA Unit Uplift Components



Local Reliability Cost - NYC & LONGIL Monthly RT BPCG, DAM BPCG, DAMAP & Minimum Oil Burn Costs



Local Reliability Cost - Rest of State Monthly RT BPCG, DAM BPCG & DAMAP Costs




Local Reliability Commitments June 2026 DARU & SRE Hours




TCC Monthly Reconfiguration Auction vs. Monthly DAM Average with Spring 2026 Centralized TCC Auction Six-Month Average


Selected Internal Path Congestion




West to Dunwoodie Path Congestion



Selected External Path Congestion





Price Change Summary:

The decrease in the price was due to the [Champlain Hudson Power Express \(CHPE\) In-Service ICAP Market Parameters](#) becoming effective July 2026.

Appendix A –Metric Definitions

- **Alert State:** The number of Alert State declarations reflect system operating conditions beyond thresholds associated with Normal and Warning States. Declaration of the Alert State allows the NYISO to take corrective actions not available in the Normal and Warning States.
- **Average Hourly Error %:** Average value of the ratio of hourly average error magnitude to hourly average actual load demand.
- **Capacity Factor:** The ratio of actual energy produced to the maximum energy that could have produced if operating at full capacity continuously during the same period.
- **Curtailed Energy:** Difference between real-time wind/FTM solar forecast and economic wind/FTM solar output limit.
- **Curtailed Energy %:** The ratio of curtailed energy to total energy production.
- **Day-Ahead Average Hourly Error %:** Average across all hours of the month of the absolute value of the difference between actual load demand and the Day-Ahead forecast load demand, divided by the actual load demand.
- **Day-Ahead Bias:** Avg (actual generation – Day-Ahead forecast generation) / capacity
- **Day-Ahead MAE Forecast Error:** Avg |actual generation – Day-Ahead forecast generation| / Capacity
- **Day-Ahead Market Capacity Unavailable:** Unavailable capacity is calculated as the difference of Day-Ahead Market capacity including SRE relative to the real-time (RT) capacity during RT peak load hour.
- **Desired Net Interchange (DNI):** A mechanism used to set and maintain the desired Energy interchange (or transfer) between two Control Areas; it is scheduled ahead of time and can be changed manually in real-time.
- **Disturbance Control Standard Event Time:** For NYISO initiated NERC Reportable Disturbances, the maximum ACE recovery time is identified. Recovery times less than 15 minutes are considered NERC compliant.
- **Hour-Ahead Bias:** Avg (actual generation – Hour-Ahead forecast generation) / capacity
- **Hour-Ahead MAE Forecast Error:** Avg |actual generation – Hour-Ahead forecast generation| / Capacity
- **Hour-Ahead MAE Persistence Error:** Avg |actual generation – Hour-Ahead actual generation| / Capacity
- **Hourly Error MW:** Value of the difference between the hourly average actual load demand and the average hour ahead forecast load demand.
- **Major Emergency:** The number of Major Emergency State declarations reflect system operating conditions beyond thresholds associated with the Alert State. Declaration of the Major Emergency State allows the NYISO to take additional corrective actions not available in the Alert State.
- **NERC Balancing Authority ACE Limit Standard:** The amount of time the clock-minute average ACE exceeds the clock-minute Balancing Authority ACE Limit (BAAL) is an indicator of the NYISO Area resource and demand balancing. The maximum BAAL exceedance time is identified. BAAL exceedances of less than 30 consecutive clock-minutes are NERC compliant.
- **NERC Control Performance Standard:** The value of NERC Control Performance Standard 1 (CPS-1) is an indicator of the NYISO Area resource and demand balancing. CPS-1 values greater than 100% are considered NERC compliant.
- **NERC IROL Time Over Limit:** For IROL exceedances leading to Major Emergency State declarations, the maximum IROL exceedance time is identified. IROL exceedances of less than thirty minutes are considered NERC compliant.
- **NERC Transmission Loading Relief (TLR):** Value represents the number of hours in which the NYISO requested TLR level 3 curtailments to provide transmission constraint relief.
- **Net Load:** Defined as Gross load less wind and solar generation.
- **Net Load Ramp:** Average value of the difference in load demand between the previous and current hour. Wind and solar ramps are negated to indicate their impact on Net load ramp.
- **Reserve Activation:** NYISO Reserve Activations are indicators of the need to respond to unexpected operational conditions within the NYISO Area or to assist a neighboring Area (Simultaneous Activation of Reserves) by activating an immediate resource and demand balancing operation.
- **Thunderstorm Alert (TSA):** TSA is declared by NYISO when severe operating conditions are detected. A predetermined set of pre-and post-contingency constraints are passed to the RTC and RTD programs while TSA is in effect. Value represents number of hours TSA was active.
- **13 Month Trailing Avg Carbon Emissions Free %:** Sum of internal NYCA generation from Nuclear, Hydro, Wind, Solar resources divided by Gross Load. Gross load is defined as metered load plus BTM solar estimated actuals.
- **13 Month Trailing Avg Renewables %:** Sum of internal NYCA generation from Hydro, Wind, Solar resources divided by Gross Load. Gross load is defined as metered load plus BTM solar estimated actuals.

Appendix B –NYISO Information Resources

- [Annual Renewable Energy Performance Metrics](#)
- [Demand Response - NYISO](#)
- [Energy Market & Operational Data](#)
- [FERC Order 844 Zonal and Resource Specific Uplift Reports](#)
- [Installed Capacity Market Data](#)
- [Load & Capacity Data Report \(Gold Book\)](#)
- [Operating Committee - NYISO](#)
- [Systems Operations Advisory Subcommittee Report](#)
- [Transmission Congestion Contracts Market Data](#)