

# New Generator Screening - 2027-2028 IRM FBC

 Generators meeting all criteria and recommended for addition

 Generators meeting 3 of 4 criteria

 Generators meeting 2 or fewer criteria

| S.no | Queue Pos.  | Project Name                  | Unit Type | Zone | SP (MW) | WP (MW) | Status | Proposed COD | 2026 RNA (Prelim.) | Customer Registration (CR) | Already Included | NYISO Recommendation For FBC | Screening Criteria Met (0-4) | Reason(s)                                       |
|------|-------------|-------------------------------|-----------|------|---------|---------|--------|--------------|--------------------|----------------------------|------------------|------------------------------|------------------------------|-------------------------------------------------|
| 1    | 811         | Cider Solar                   | S         | B    | 500.0   | 500.0   | 12     | 01-2027      | Y                  | Y                          | Y                | Include                      | 4                            | Meets all criteria                              |
| 2    | 596         | Alle Catt II Wind             | W         | A    | 339.1   | 339.1   | 12     | 12-2026      | Y                  | Y                          | Y                | Include                      | 4                            | Meets all criteria                              |
| 3    | 721         | Excelsior Energy Center       | S         | B    | 280.0   | 280.0   | 12     | 11-2026      | Y                  | Y                          | Y                | Include                      | 4                            | Meets all criteria                              |
| 4    | 931         | Astoria Energy Storage        | ES        | J    | 100.0   | 100.0   | 12     | 10-2026      | Y                  | Y                          | Y                | Include                      | 4                            | Meets all criteria                              |
| 5    | EDS 2025-02 | Curtis and Palmer             | HY        | F    | 58.8    | 58.8    | I/S    | I/S          | N/A                | Y                          | N                | Include                      | 4                            | Meets all criteria                              |
| 6    | 734         | Ticonderoga Solar             | S         | F    | 20.0    | 20.0    | 11     | 12-2026      | Y                  | Y                          | N                | Include                      | 4                            | Meets all criteria                              |
| 7    | 827         | Arthur Kill Energy Storage 1  | ES        | J    | 15.0    | 15.0    | 12     | 12-2026      | Y                  | Y                          | Y                | Include                      | 4                            | Meets all criteria                              |
| 8    | EDS 2024-01 | Orangeville ESR               | ES        | C    | 10.0    | 10.0    | I/S    | I/S          | N/A                | Y                          | Y                | Include                      | 4                            | Meets all criteria                              |
| 9    | EDS 2024-01 | Pomona ESR                    | ES        | G    | 3.0     | 3.0     | I/S    | I/S          | N/A                | Y                          | Y                | Include                      | 4                            | Meets all criteria                              |
| 10   | 766         | Sunrise Wind                  | W         | K    | 880.0   | 880.0   | 12     | 10-2027      | Y                  | Y                          | N                | Exclude                      | 3                            | COD after June 2027                             |
| 11   | 737         | Empire Wind 1                 | W         | J    | 816.0   | 816.0   | 12     | 09-2027      | Y                  | Y                          | N                | Exclude                      | 3                            | COD after June 2027                             |
| 12   | 987         | Sunrise Wind II               | W         | K    | 44.0    | 44.0    | 12     | 10-2027      | Y                  | Y                          | N                | Exclude                      | 3                            | COD after June 2027                             |
| 13   | 564         | Rock District Solar           | S         | F    | 20.0    | 20.0    | 11     | 02-2027      | Y                  | N                          | N                | Exclude                      | 3                            | Did not commence customer registration (CR)     |
| 14   | 584         | Dog Corners Solar             | S         | C    | 20.0    | 20.0    | 12     | 01-2027      | Y                  | N                          | N                | Exclude                      | 3                            | Did not commence CR                             |
| 15   | 586         | Watkins Rd Solar              | S         | E    | 20.0    | 20.0    | 12     | 02-2027      | Y                  | N                          | N                | Exclude                      | 3                            | Did not commence CR                             |
| 16   | 804         | KCE NY 10                     | ES        | A    | 20.0    | 20.0    | 11     | 10-2026      | Y                  | N                          | N                | Exclude                      | 3                            | Did not commence CR                             |
| 17   | 828         | Valley Solar                  | S         | C    | 20.0    | 20.0    | 12     | 01-2027      | Y                  | N                          | N                | Exclude                      | 3                            | Did not commence CR                             |
| 18   | 1003        | Clear View Solar              | S         | C    | 20.0    | 20.0    | 11     | 08-2026      | Y                  | N                          | N                | Exclude                      | 3                            | Did not commence CR                             |
| 34   | 572         | Greene County 1               | S         | G    | 20.0    | 20.0    | 11     | 06-2027      | Y                  | N                          | N                | Exclude                      | 3                            | Did not commence CR                             |
| 38   | 832         | CS Hawthorn Solar             | S         | F    | 20.0    | 20.0    | 11     | 06-2027      | Y                  | N                          | N                | Exclude                      | 3                            | Did not commence CR                             |
| 47   | 573         | Greene County 2               | S         | G    | 10.0    | 10.0    | 11     | 06-2027      | Y                  | N                          | N                | Exclude                      | 3                            | Did not commence CR                             |
| 19   | 519         | Canisteo Wind                 | W         | C    | 290.7   | 290.7   | 11     | 05-2028      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 20   | 883         | Garnet Energy Center          | S         | B    | 200.0   | 200.0   | 11     | 04-2028      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 21   | 950         | Hemlock Ridge Solar           | S         | B    | 200.0   | 200.0   | 11     | 04-2028      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 22   | 710         | Horseshoe Solar               | S         | B    | 180.0   | 180.0   | 11     | 05-2028      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 23   | 801         | Prattsburgh Wind Farm         | W         | C    | 147.0   | 147.0   | 11     | 09-2027      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 24   | 571         | Heritage Wind                 | W         | B    | 126.0   | 126.0   | 11     | 10-2027      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 25   | 1079        | Somerset Solar                | S         | A    | 125.0   | 125.0   | 11     | 06-2028      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 26   | 880         | Brookside Solar               | S         | D    | 100.0   | 100.0   | 11     | 12-2027      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 27   | 716         | Moraine Solar Energy Center   | S         | C    | 93.5    | 93.5    | 11     | 09-2028      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 28   | 276         | Homer Solar Energy Center     | S         | C    | 90.0    | 90.0    | 11     | 06-2028      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 29   | 720         | Trelina Solar Energy Center   | S         | C    | 79.8    | 79.8    | 11     | 04-2028      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 30   | 644         | Columbia County 1             | S         | F    | 60.0    | 60.0    | 11     | 02-2027      | N                  | N                          | N                | Exclude                      | 2                            | Not Included in RNA, did not commence CR        |
| 31   | 815         | Bayonne Energy Center III     | ES        | J    | 49.8    | 49.8    | 12     | 07-2027      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 32   | EDS 2024-01 | Brigis 2                      | ES        | J    | 20.0    | 20.0    | N/A    | 06-2026      | N/A                | N                          | N                | Exclude                      | 2                            | Developer Indicated COD Delay to 2028           |
| 33   | EDS 2024-01 | Juniper Valley                | ES        | J    | 20.0    | 20.0    | N/A    | 06-2026      | N/A                | N                          | N                | Exclude                      | 2                            | Limited information publically available        |
| 35   | 575         | Little Pond Solar             | S         | G    | 20.0    | 20.0    | 11     | 09-2027      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 36   | 581         | Hills Solar                   | S         | E    | 20.0    | 20.0    | 11     | 04-2028      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 37   | 670         | SunEast Skyline Solar LLC     | S         | E    | 20.0    | 20.0    | 11     | 04-2028      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 39   | 833         | Dolan Solar                   | S         | F    | 20.0    | 20.0    | 11     | 09-2027      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 40   | 865         | Flat Hill Solar               | S         | E    | 20.0    | 20.0    | 12     | 08-2027      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 41   | 885         | Grassy Knoll Solar            | S         | E    | 20.0    | 20.0    | 11     | 05-2028      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 42   | 1015        | Somers Solar, LLC             | S         | F    | 20.0    | 20.0    | 11     | 12-2027      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 43   | 1047        | Millers Grove Solar           | S         | E    | 20.0    | 20.0    | 11     | 03-2028      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 44   | 1329        | ELP Granby Solar II           | CR        | C    | 20.0    | 20.0    | 11     | 06-2028      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 45   | 590         | Scipio Solar                  | S         | C    | 18.0    | 18.0    | 12     | 09-2027      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 46   | 1166        | BR Benson Mines Solar         | S         | E    | 12.1    | 12.1    | 11     | 12-2027      | Y                  | N                          | N                | Exclude                      | 2                            | COD after June 2027, did not commence CR        |
| 48   | EDS 2021-01 | West Babylon Energy Storage   | ES        | K    | 9.9     | 9.9     | N/A    | 08-2026      | N/A                | N                          | N                | Exclude                      | 2                            | Delayed due to siting/permitting considerations |
| 55   | 1007        | NYC Energy LLC - Phase 2      | ES        | J    | 220.1   | 220.1   | 12     | 06-2027      | N                  | N                          | N                | Exclude                      | 2                            | Not Included in RNA, did not commence CR        |
| 57   | 683         | KCE NY 2                      | ES        | G    | 200.0   | 200.0   | 11     | 06-2027      | N                  | N                          | N                | Exclude                      | 2                            | Not Included in RNA, did not commence CR        |
| 70   | 522         | NYC Energy                    | ES        | J    | 79.9    | 79.9    | 12     | 06-2027      | N                  | N                          | N                | Exclude                      | 2                            | Not Included in RNA, did not commence CR        |
| 49   | EDS 2025-02 | KCE NY 14                     | ES        | G    | 20.0    | 20.0    | N/A    | 12-2027      | N/A                | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria               |
| 50   | EDS 2025-02 | Soltage Jamaica               | ES        | J    | 20.0    | 20.0    | N/A    | N/A          | N/A                | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria               |
| 51   | EDS 2025-02 | RP New York BESS              | ES        | J    | 5.1     | 5.1     | N/A    | N/A          | N/A                | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria               |
| 52   | 783         | South Ripley Solar and BESS   | CR        | A    | 270.0   | 270.0   | 11     | 12-2027      | N                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria               |
| 53   | 1031        | Mill Point Solar              | CR        | E    | 250.0   | 250.0   | 10     | 12-2028      | Y                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria               |
| 54   | 1183        | NY125A - Fort Covington Solar | S         | D    | 250.0   | 250.0   | 10     | 07-2028      | Y                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria               |

# New Generator Screening - 2027-2028 IRM FBC

 Generators meeting all criteria and recommended for addition

 Generators meeting 3 of 4 criteria

 Generators meeting 2 or fewer criteria

| S.no | Queue Pos. | Project Name                          | Unit Type | Zone | SP (MW) | WP (MW) | Status | Proposed COD | 2026 RNA (Prelim.) | Customer Registration (CR) | Already Included | NYISO Recommendation For FBC | Screening Criteria Met (0-4) | Reason(s)                         |
|------|------------|---------------------------------------|-----------|------|---------|---------|--------|--------------|--------------------|----------------------------|------------------|------------------------------|------------------------------|-----------------------------------|
| 56   | 1122       | East Fishkill                         | ES        | G    | 205.0   | 205.0   | 11     | 12-2029      | N                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria |
| 58   | 1184       | NY125B - Two Rivers Solar             | S         | D    | 200.0   | 200.0   | 10     | 09-2028      | Y                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria |
| 59   | 620        | Gateway Solar Energy Center           | S         | D    | 180.0   | 180.0   | 11     | 04-2028      | N                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria |
| 60   | 1009       | Yellow Barn Solar                     | S         | C    | 160.0   | 160.0   | 10     | 11-2028      | Y                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria |
| 61   | 777        | White Creek Solar                     | S         | B    | 135.0   | 135.0   | 11     | 06-2028      | N                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria |
| 62   | 971        | East Setauket Energy Storage          | ES        | K    | 125.0   | 125.0   | 10     | 04-2027      | N                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria |
| 63   | 864        | NY38 Solar                            | S         | E    | 120.0   | 120.0   | 11     | 04-2028      | N                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria |
| 64   | 774        | Tracy Solar Energy Center             | S         | E    | 119.0   | 119.0   | 10     | 12-2028      | Y                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria |
| 65   | 956        | Holtsville 138kV Energy Storage       | ES        | K    | 110.0   | 110.0   | 11     | 05-2028      | N                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria |
| 66   | 637        | Flint Mine Solar                      | S         | G    | 100.0   | 100.0   | 11     | 04-2028      | N                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria |
| 67   | 704        | Bear Ridge Solar                      | S         | A    | 100.0   | 100.0   | 10     | 04-2028      | Y                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria |
| 68   | 495        | Mohawk Solar                          | S         | F    | 90.5    | 90.5    | 11     | 11-2027      | N                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria |
| 69   | 1151       | York Run Solar                        | S         | A    | 90.0    | 90.0    | 11     | 09-2028      | N                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria |
| 71   | 835        | Luyster Creek Energy Storage 1        | ES        | J    | 56.3    | 57.3    | 11     | 04-2028      | N                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria |
| 72   | 617        | Watkins Glen Solar                    | S         | C    | 50.0    | 50.0    | 11     | 04-2028      | N                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria |
| 73   | 535        | Riverhead Solar 2                     | S         | K    | 36.0    | 36.0    | 11     | 01-2028      | N                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria |
| 74   | 930        | Luyster Creek Energy Storage 3        | ES        | J    | 15.0    | 15.0    | 10     | 03-2027      | N                  | N                          | N                | Exclude                      | 1                            | Meets only one screening criteria |
| 75   | 1080       | Mineral Basin Solar Power             | S         | C    | 401.6   | 401.6   | 10     | 12-2029      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 76   | 800        | Rich Road Solar Energy Center         | CR        | E    | 240.0   | 240.0   | 10     | 04-2028      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 77   | 805        | Oxbow Hill Solar                      | S         | C    | 140.0   | 140.0   | 10     | 06-2029      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 78   | 995        | Alabama Solar Park LLC                | S         | B    | 130.0   | 130.0   | 10     | 10-2028      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 79   | 953        | Sugar Maple Solar                     | S         | E    | 125.0   | 125.0   | 10     | 12-2027      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 80   | 882        | Riverside Solar                       | S         | E    | 100.0   | 100.0   | 10     | 12-2027      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 81   | 1148       | Agricola Wind                         | W         | C    | 97.0    | 97.0    | 10     | 04-2029      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 82   | 967        | KCE NY 5                              | ES        | G    | 94.0    | 94.0    | 10     | 12-2027      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 83   | 1188       | North Seneca Solar Project, LLC       | S         | C    | 90.0    | 90.0    | 10     | 09-2027      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 84   | 907        | Harlem River Yard                     | ES        | J    | 79.9    | 79.9    | 10     | 01-2028      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 85   | 1255       | Holtsville Brookhaven Battery Storage | ES        | K    | 79.9    | 79.9    | 10     | 10-2027      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 86   | 834        | Luyster Creek Energy Storage 2        | ES        | J    | 79.0    | 79.0    | 10     | 04-2028      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 87   | 1123       | KCE NY 29                             | ES        | K    | 79.0    | 79.0    | 10     | 08-2028      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 88   | 1130       | Hoffman Falls Wind                    | W         | C    | 72.0    | 72.0    | 10     | 04-2029      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 89   | 1117       | CLIES 70MW                            | ES        | K    | 70.0    | 70.0    | 10     | 12-2027      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 90   | 1257       | Edwards Calverton Battery Storage     | ES        | K    | 60.0    | 60.0    | 10     | 11-2027      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 91   | 843        | NY37 Solar                            | S         | E    | 20.0    | 20.0    | 10     | 09-2028      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 92   | 932        | Hatchery Solar                        | S         | B    | 20.0    | 20.0    | 10     | 01-2029      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 93   | 1000       | Flat Stone Solar                      | S         | E    | 20.0    | 20.0    | 10     | 05-2028      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 94   | 1113       | CLIES 20 MW                           | ES        | K    | 20.0    | 20.0    | 10     | 12-2027      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 95   | 1237       | Sugar Maple Energy Storage            | ES        | E    | 20.0    | 20.0    | 10     | 12-2028      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |
| 96   | 863        | Highbanks Solar                       | S         | B    | 12.5    | 12.5    | 10     | 09-2029      | N                  | N                          | N                | Exclude                      | 0                            | Meets no screening criteria       |

## NOTES:

- The column labeled 'SP' refers to the maximum summer megawatt electrical output. The column labeled 'WP' refers to the maximum winter megawatt electrical output.
- The column labeled 'Status' refers to the status of the project in the NYISO's LFIP. Key: 10=Accepted Cost Allocation/IA in Progress, 11=IA Completed, 12=Under Construction, 0=Withdrawn, N/A= EDS unit with no public status, I/S = In Service
- EDS in the Queue Pos. columns refers to units which had an Expedited Deliverability Study to obtain CRIS