

**NEW YORK STATE RELIABILITY COUNCIL
EC #329 – Friday, September 11, 2026**

Status Report - RRS Meeting #313 – Thursday, September 3, 2026

♦ Introduction/RRS Actions Items and Goals

- No requests for Executive Session or Additional Agenda Items were made;
- RRS reviewed August Status Report to EC#328;
- RRS reviewed Action Items list with focus on 2026 Goals and Chair requested RRS members consider taking the lead, in conjunction with NYISO, on how to resolve NPCC Directory 1 / NYSRC Tables B-2 and C-2 language inconsistency issues;
- RRS reviewed and unanimously approved the draft Meeting Minutes for RRS #312(August)

♦ PRR in Development

- PRR 153 - TS Planning Performance Requirements - Include "Sudden loss of fuel delivery system to multiple solar & wind plants" as Category I & II Design Contingencies in Table B-1
- PRR 155 - Establish minimum interconnection standards for Large Inverter Based Resource (IBR) Generating Facilities based on IEEE Standard 2800-2022
 - Roger Clayton lead the discussion of proposed changes to RR B.5 to include "as- built" IBR Facilities along with the proposed changes to the procedures document, and
 - After several questions were discussed, RRS unanimously moved to recommend PRR 155 and the revised Procedures be brought to the Executive Committee for approval to post for the 45-day public comment period
- PRR 157 – Mandatory Under-Frequency Load Shedding (UFLS) Design Requirements for Large Load Facilities
 - RRS discussed questions raised during last month's Executive Committee and Large Load Working Group meetings;
 - Question was raised whether all comments would be available for RRS to recommend final approval at its upcoming meeting, which convenes October 1 and whether addressing significant comments with rule revisions could cause RRS to recommend a revised rule be re-posted for Comment.
 - Chair announced that it would be presenting PRR 157 to NYISO stakeholders at the September 14 ESPWG
- PRR 161– Updates to RR C.7 Consistent with Updates to Policy 1, Section 5
 - No new discussion on PRR 161
- PRR 162 and PRR 163 – Modification to the underground cable operating and planning criteria found in Table C-2 and Table B-2, respectively
 - Martin Paszek was unable to attend the meeting
 - Keith Burrell of NYISO indicated that NYISO has been delayed in reviewing changes made to its draft PRR 163 as suggested by Martin Paszek at the July

9 RRS and that additional delay in approving a final ruleset with updates added to Table B-2 to reflect the changes to the underground cable operating criteria made to Table C-2 in PRR 159 would likely have no impact on near term planning studies.

- While RRS had previously moved to recommend the EC post both 162 and 163 for comment pending NYISO's agreement to the changes to PRR 163 requested by Con Edison, RRS did not elect to move the ruleset forward without NYISO's and Con Edison's agreement on the proposed language

◆ **PRRs Posted for Comment**

- PRR 155 – “Establish minimum interconnection standards for Large Inverter Based Resource (IBR) Generating Facilities based on IEEE Standard 2800-2022” is being recommended to the EC for approval to post
- PRR 157 – “Mandatory Under-Frequency Load Shedding (UFLS) Design Requirements for Large Load Facilities” has been posted for comments, which are due on October 1, 2026
- PRR 161 – “Updates to RR C.7 Consistent with Updates to Policy 1, Section 5” has been posted for comments, which are due on October 1, 2026

◆ **PRRs Under Review following Posting**

- None

◆ **PRRs for Final Approval**

- None

◆ **Other RRS Matters**

- Chair indicated that responses to the worksheet regarding the “Blackstart Resource Availability and Readiness in the Eastern and Western Interconnections, NERC and Regional Entity Staff Study, FERC Staff Observation” (the “Study”) will be discussed at the October 1 RRS meeting (5 of 6 members have responded and the final response is expected to be received shortly allowing the chair to meet with NYISO and develop proposal for responding to the Executive Committee);
- Leka Gjonaj presented the NERC Standards Tracking, which he had requested comments be provided by today
- Chair reminded RRS members to attend September 14 ESPWG regarding PRR 157 discussion and that the November 5th meeting is being moved to Friday, November 6, 2026, at 10 a.m.

◆ **Next Meeting RRS #314, Thursday, October 1, 2026, via Webex following RCMS**