NEW YORK STATE RELIABILITY COUNCIL
MEETING OF THE RELIABILITY RULES SUBCOMMITTEE
Minutes RRS Meeting #314
10:40 AM, Thursday, October 1, 2026

RRS Members and Alternatives:

David Allen	Consultant	Chairman
Myles Shipe	Central Hudson	Alternate Member
Brian Shanahan	National Grid	Member
Brian Gordon	NYSEG	Alternate Member
Saud Amin	Con Edison	Alternate Member
Libin Varghese	NYPA	Member
Arif Hossain	NYPA	Alternate Member
Luke Figliozzi	PSEGLI	Member
Robert Eisenhuth	PSEGLI	Alternate Member

Guests:

Denise DeChairo	NYISO
Greg Campoli	NYISO
Keith Burrell	NYISO
Leka Gjonaj	RCMS Chair
Mark Capano	NextEra

NEW YORK STATE RELIABILITY COUNCIL
MEETING OF THE RELIABILITY RULES SUBCOMMITTEE
Minutes RRS Meeting #314
10:40 AM, Thursday, October 1, 2026

1. Introduction
   1.1. Executive Session (if requested) – *none requested*
   1.2. Requests for Additional Agenda Items – *none requested*

2. Approval of Minutes/Action Items
   2.1. RRS 313 Status Report to Executive Committee – 🗎 – *D. Allen reviewed the meeting report.*
   2.2. RRS 313 Action Items List & Final 2026 RRS Goals – 🗎 – *D. Allen reviewed full list noting status.*
   2.3. RRS 313 (September 3) Approval of Minutes – 🗎 – *D. Allen reviewed. M. Shipe motioned to approve the minutes, B. Shanahan seconded, No objections, no abstentions. Motioned carried.*

3. NYSRC Reliability Rules Development
   3.1. PRR List Outstanding – 🗎 – *D. Allen reviewed the list noting progress, 155, 157 & 161 currently posted for comment.*

   3.2. PRRs in Development
      3.2.1. PRR 153: "Sudden loss of fuel delivery system to multiple solar & wind plants" as Category I & II Design Contingencies in Table B-1 – *D. Allen reviewed the status.*

      3.2.2. PRR 155: Establish minimum interconnection standards for Large Inverter Based Resource (IBR) Generating Facilities based on IEEE Standard 2800-2022 – 🗎 – *D. Allen reviewed final clean rule.*

      3.2.3. PRR 157: "Mandatory Under-Frequency Load Shedding (UFLS) Design Requirements for Large Load Facilities" – 🗎 – *D. Allen reviewed the rule and discussed follow-ups from the EC. Concern surrounding the use of "Large Load" without defining it, and how this rule will apply to existing loads. Reviewed comment received from Black Flare, inc. and discussed with the group. It was also noted that a comment form will be created for responses from the RRS.*

      3.2.4. PRR 161: "Updates to RR C.7 regarding Exception Process Consistent with Changes to Policy 1, Section 5" – 🗎 – *D. Allen reviewed the status. It was also noted that the comment period ends 10/1.*

      3.2.5. PRR 162: "Modification to the underground cable operating criteria Table C-2" – 🗎 – *D. Allen/ NYISO noted interest in moving this rule forward for the next meeting to the EC.*

      3.2.6. PRR 163: "Modification to the underground cable planning criteria Table B-2" – 🗎 – *D. Allen noted RRS is awaiting NYISO review and confirmation of the latest drafts. S. Amin confirmed that ConEd has not received any word from the NYISO.*

4. Black Start Study
   4.1. Blackstart Resource Availability and Readiness in the Eastern and Western Interconnections / Status of Worksheet Responses – *D. Allen noted all have been received, will compile them together, and send to the NYISO.*

5. Action Items for Large Load Working Group for 2027 – *D. Allen*

6. NERC SARS/Organization Standards
   6.1. NERC Standard Tracking – 🗎 – *L. Gjonaj reviewed current balloting, Computation load balloting passed-*

CLO-001, CLO-002, CLO-003.

7. Reports
   - 7.1. NYSRC EC September 11, 2026, Meeting Report – *D. Allen provided a brief report on the EC Meeting.*
   - 7.2. IBR Working Group Status Report – *R. Clayton/D. Allen*
   - 7.3. Extreme Weather Working Group Meeting Report – *H. Athar/D. Allen*
   - 7.4. NYSRC ICS Meeting Report – *B. Shanahan reviewed the ICS meeting report.*
   - 7.5. Large Load WG Meeting Report – *B. Schultz/D. Allen*

8. Next Meeting #315: Friday, November 6, 2026 @ 10:00 AM – Webex

B. Shanahan motioned to adjourn, D. Allen seconded, RRS #314 concluded at 12:00 pm.